



Distance of LPG exchange cylinder from source of ignition.
This diagram is in accordance with Standard AS/NZS 2430.3
*This dimension is measured from the top of any cylinder valve

Door
1000mm
minimum

Opening window
150mm
minimum

Air vent or opening
1000mm
minimum

Drain
1000mm
minimum